





DELAWARE STATE FIRE MARSHAL  
FIRE ALARM SYSTEM  
CERTIFICATE OF INSPECTION



**MINOR DEFICIENCIES IDENTIFIED DURING INSPECTION:**

- |             |   |   |             |   |   |
|-------------|---|---|-------------|---|---|
| <u>7620</u> | - | Battery / Secondary Power out-of-service                          | <u>7630</u> | - | Tamper Switch not Connected to FASS     |
| <u>7621</u> | - | A Battery out-of-date / Corroded                                  | <u>7631</u> | - | Manual Pull Station Obstructed          |
| <u>7622</u> | - | Smoke / Heat / Flame Detector Damaged                             | <u>7632</u> | - | Manual Pull Station Damaged             |
| <u>7623</u> | - | Smoke Detector too Close to Diffuser / Vent                       | <u>7633</u> | - | Bell, Horn / Strobes Damaged            |
| <u>7624</u> | - | Smoke Detector / Heat Detector not connected to FAP               | <u>7634</u> | - | Bell, Horn / Strobes Lacking Audibility |
| <u>7625</u> | - | Smoke Detector not A/C Powered with Battery Back-Up (Residential) | <u>7635</u> | - | Bell, Horn / Strobes Damaged / Missing  |
| <u>7626</u> | - | Inadequate Detector Coverage                                      | <u>7636</u> | - | Device Identification Lacking           |
| <u>7627</u> | - | Duct Detector Inoperative   | <u>7637</u> | - | Circuit Breaker to FACP no Lockout      |
| <u>7628</u> | - | Duct Detector Lacking System Shut-Down                            | <u>7638</u> | - | Supervisory Function Deficiency         |
| <u>7629</u> | - | Flow / Pressure Switch not Connected to FASS                      | <u>7639</u> | - | Other                                   |