



**DELAWARE STATE FIRE MARSHAL
STANDPIPE SYSTEMS
DEFICIENCY REPAIR FORM**



PROTECTED PROPERTY

Name: _____ Owner/Contact: _____
Address/City: _____ Phone Number: _____

SUPPRESSION SYSTEM COMPANY AND REPAIR DATE

Company Name: _____ FSL #: _____
Technician's Name: _____ Repair Date: _____

SYSTEM INFORMATION

System ID Number: _____ Location: _____

System Type: Wet Standpipe Dry Standpipe Other
Operation: Manual Semi-Automatic Automatic

MAJOR DEFICIENCIES CORRECTED

NONE CHECKED BELOW

HOSE CONNECTIONS

- 7501 – Visible Obstructions
- 7502 – Fire Hose Connection Damaged
- 7503 – Valve Handles Missing
- 7504 – Valve Leaking

CABINET

- 7506 – Visible Obstructions

HOSE STORAGE DEVICE

- 7507 – Obstruction
- 7508 – Other (Comment Below)

PIPING

- 7505 – Damaged Piping

NONE CHECKED BELOW

MINOR DEFICIENCIES CORRECTED

HOSE CONNECTIONS

- 7550 – Cap Missing
- 7551 – Cap Gasket Missing or Deteriorated
- 7552 – Restricting Device Missing
- 7553 – Manual, Semi-Automatic or Dry-Standpipe—Valve Does Not Operate Smoothly

HOSE STORAGE DEVICE

- 7562 – Difficult to Operate
- 7563 – Damaged
- 7564 – Hose Improperly Racked or Rolled
- 7565 – Nozzle Clip In Place and Nozzle Correctly Contained
- 7566 – If Exposed In Cabinet, Will Hose Rack Swing Out At Least 90 Degrees?

PIPING

- 7554 – Control Valves Damaged
- 7555 – Missing or Damaged Pipe Support Devices
- 7556 – Damaged Supervisory Devices

CABINET

- 7567 – Difficult to Open
- 7568 – Cabinet Door Will Not Open Fully
- 7569 – Door Glazing Cracked or Broken
- 7570 – If Cabinet Is Break-Glass Type, Is Lock Functioning Properly?
- 7571 – Glass Break Device Is Missing or Not Attached
- 7572 – Not Properly Identified As Containing Fire Equipment
- 7573 – All Valves, Hose, Nozzles, Fire Extinguishers, etc., Easily Accessible

HOSE

- 7557 – Hose Missing
- 7558 – Hose Damaged or In Poor Condition

HOSE NOZZLE

- 7559 – Hose Nozzle Missing
- 7560 – Gasket Missing or Deteriorated
- 7561 – Nozzle Does Not Operate Smoothly

COMMENTS/DEFICIENCY DESCRIPTION
